

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 3175-1443:100

Page 1 of 1

CATEGORY: Air Filter Units

LISTEE: AAF International, PO Box 35690, Louisville KY 40232-5690
Contact: David W. Miller (502) 637-0518

DESIGN: *Model AMER-GLAS air filter units (media and framed unit). The framed unit consists of an adhesive coated, disposable fiberglass media, 28 Ga. metal grilles front and back, 1/2" to 3-3/4" thick, any size perimeter dimensions available. The media unit consists of a disposable air filter roll fiberglass media and unit pads with an adhesive coated. Rolls size from 1/2" to 3-3/4" thickness, 8" to 6' wide. Pad sizes from 1/2" to 3-3/4" thickness, any size perimeter dimensions available (cut as requested). Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, media description and UL label.

APPROVAL: Listed as a Class II media or framed air filter unit for use within HVAC systems.

NOTE: Formerly 3175-1390:100 and 3175-1443:101*

*Corrected 06-19-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 15, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager